

RQY


Connectors FLEXAquick for ROHRflex corrugated plastic tubings

Plastic Y distributor for rational tubing assembly by just putting on

Temperature: -40°C ... +120°C

Material: TPE plastics

IP class [acc. to EN 60529]: IP 66



APPLICATIONS:

- Application: machine and plant constructions / insulated electrical installations for application rules machine and plant constructions acc. to DIN EN 60204



FLEXA No.	Colour	OD [mm]	Ø B1 [mm]	Ø B2 [mm]	D [mm]	C [mm]	Ø F [mm]	Weight [kg/100]	PU [pcs.]
15020033205	Black	OD1 - 10,0 / OD2 - 2 x 10,0	17,5	17,5	54,5	36,5	4,0	0,630	10
15020033206	Black	OD1 - 21,2 / OD2 - 2 x 15,8	29,5	25,0	75,0	52,0	4,0	2,600	10
15020033213	Black	OD1 - 28,5 / OD2 - 2 x 15,8	36,5	25,0	75,0	52,0	4,0	2,800	10
15020033212	Black	OD1 - 18,5 / OD2 - 2 x 18,5	26,5	26,5	81,0	54,5	4,0	2,200	10
15020033207	Black	OD1 - 21,2 / OD2 - 2 x 21,2	29,5	29,5	82,5	62,5	4,0	2,900	10
15020033208	Black	OD1 - 28,5 / OD2 - 2 x 21,2	36,5	29,5	81,5	61,5	4,0	3,500	10
15020033209	Black	OD1 - 34,5 / OD2 - 2 x 28,5	42,5	36,5	86,0	79,0	4,0	5,200	10
15020033210	Black	OD1 - 42,5 / OD2 - 2 x 34,5	52,5	42,5	98,5	89,0	4,0	6,500	10
15020033211	Black	OD1 - 54,5 / OD2 - 2 x 42,5	65,0	52,5	116,0	109,5	4,0	11,600	5
15020033005	Grey	OD1 - 10,0 / OD2 - 2 x 10,0	17,5	17,5	54,5	36,5	4,0	0,630	10
15020033006	Grey	OD1 - 21,2 / OD2 - 2 x 15,8	29,5	25,0	75,0	52,0	4,0	2,600	10
15020033007	Grey	OD1 - 21,2 / OD2 - 2 x 21,2	29,5	29,5	82,5	62,5	4,0	2,900	10
15020033008	Grey	OD1 - 28,5 / OD2 - 2 x 21,2	36,5	29,5	81,5	61,5	4,0	3,500	10
15020033009	Grey	OD1 - 34,5 / OD2 - 2 x 28,5	42,5	36,5	86,0	79,0	4,0	5,200	10

Recommendations for any areas of applications, products, or product combinations are issued to the best of FLEXA's knowledge and experience. The user is requested to check applicability of FLEXA products to specific applications and purposes prior to the use of the particular products. All documentation, illustrations, and charts published are subject to copyright and must not be copied, changed, used, or modified. Technical drawings, certificates, authorizations, and results by the FLEXA lab will be provided upon request. FLEXA will not be held liable for typographical or other errors and incorrect drawings. Technical modifications are subject to change without prior notice.